

Rules For Approved Water Haulers

The Municipality reserves the right to revoke any permits if these guidelines are not followed. These guidelines do not supersede or replace the Nova Scotia Environments "Portable Water Hauler Guidelines "

- Bulk water vehicles are to be inspected annually by WHRM to ensure the vehicles are compatible with our system. Upon satisfactory inspection a permit will be issued to be displayed on the vehicle, preferably on the back of the tank.
PERMIT IS NOT TRANSFERABLE
- Bulk water haulers acknowledge that the water has left the custody of West HANTS Regional Municipality's Water Utility, and the Municipality is not responsible for the water quality since it has left the water system.
- Bulk Water Haulers release West Hants Regional Municipality from any and all claims that they may have arisen from and impurity on the water and agree to save the Municipality harmless from any claim based on the quality of the water made by any person who obtained water from them.
- Vehicles require Cam-lock adapter, Rigid piping permanently attached to vehicle and an air gap twice the diameter of the pipe.
Tank must be designated for hauling water only and have a fixed air gap of 2x the pipe diameter.
- Any chemical addition by the water hauler must be done after the tank has been filled & not at the bulk water station site.
- Report lost activation Key Fob(s) It may take up to 48 hours to replace Key Fob. Fobs will not be replaced on weekends or holidays.
- Issues with the Water haul Station can be reported to West Hants Public Works 902-798-8391 Ext 125 (902-798-7080) if it is after hour emergency with the station)